



Inspection report

Date: 25.10.11	Job nr.:	Weather:	Operator: Pat	section number: 1	PLR: FMH1 X
Present:	Vehicle: Survey Unit 2	Camera: Atex 4	Preset:	Cleaned: Yes	Grade:

Road: SAMPLE REPORT	Division:	start MH: FMH1
Place:	District:	end MH: Downstream
Location:	Tape No.: 1	Total length: 91.3 m

Purpose: Asset condition	Size/Shape: Circular 225
Use: Foul	Material: Concrete Pipe length:
Catchment:	Lining: None
	Category:

Comment:
Location details:

1:675	position	code	observation	grade	
	0.00	MH	Manhole Remark: FMH1	(Constr)	
	0.00	WL	Water level, 10 % height/diameter, Remark: Flowing	(Serv) 0	
	1.00	ST	Start of survey	(Misc) 0	
	10.80	CN	Connection, at 09 o'clock, dia 100 mm, Remark: Plugged	(Constr)	
	13.60	CN	Connection, at 09 o'clock, dia 100 mm, Remark: Plugged	(Constr)	
	16.80	GO	General Observation - Manhole	(Misc) 0	
	19.00	CN	Connection, at 12 o'clock, dia 100 mm	(Constr)	
	21.20	CN	Connection, at 09 o'clock, dia 100 mm	(Constr)	
	25.00	CNI	Connection, at 12 o'clock, dia 100 mm, intrusion 50 mm	(Constr) 4	
	35.70	CN	Connection, at 09 o'clock, dia 100 mm, Remark: Plugged	(Constr)	
	43.90	CN	Connection, at 09 o'clock, dia 100 mm, Remark: Plugged	(Constr)	
	49.60	CN	Connection, at 09 o'clock, dia 100 mm, Remark: Plugged	(Constr)	
	53.20	CN	Connection, at 09 o'clock, dia 100 mm, Remark: Plugged	(Constr)	
	61.80	CL	Longitudinal Crack, at 02 o'clock	(Struct) 2	
	61.90	CC	Circumferential Crack, from 12 to 02 o'clock	(Struct) 2	
	66.00	CN	Connection, at 09 o'clock, dia 100 mm	(Constr)	
	71.80	CN	Connection, at 12 o'clock, dia 100 mm, Remark: Possibly Plugged	(Constr)	
	76.00	CN	Connection, at 09 o'clock, dia 100 mm	(Constr)	
	76.00	GO	General Observation - Suspect Root Infiltration at Connection	(Misc) 0	
	78.20	RFJ	Fine Roots at joint, at 02 o'clock	(Serv) 1	
	82.50	CN	Connection, at 09 o'clock, dia 100 mm	(Constr)	
	91.30	GO	General Observation - Manhole	(Misc) 0	
	91.30	FH	Finish survey	(Misc) 0	

Structural Defects	Constructional Features
Service Defects	Miscellaneous Features